

EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085AQ0287

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) <i>EG-Gasgeräte-Richtlinie (2009/142/EG)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	SIT la precisa S.p.A. Viale dell'Industria, 31/33, I-35129 Padova
Distributor <i>Vertreiber</i>	SIT la precisa S.p.A. Viale dell'Industria, 31/33, I-35129 Padova
Product Category <i>Produktart</i>	accessories for gas appliances/pressure equipment: Multi functional control (4104)
Product Description <i>Produktbezeichnung</i>	Multifunctional control, consisting of manual tap, thermoelectric flame supervision, pressure regulator, temperature controller and reclosing interlock
Model <i>Modell</i>	710 Minisit
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, SE, SI, SK
Test Reports <i>Prüfberichte</i>	supplement test: 113513B3 from 24.06.2013 (GWI)
Test Basis <i>Prüfgrundlagen</i>	EU/2009/142/EG (30.11.2009) DIN 3446 (01.08.1983) DIN EN 88 (01.09.1991) DIN EN 257 (01.03.1992) DIN EN 126 (01.04.1993)- under consideration DIN 3393-1 (01.01.1973) DIN EN 125 (01.09.1991)
File Number <i>Aktenzeichen</i>	13-0141-GEA

08.07.2013 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive 2009/142/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888

Fax +49 228 91 88 - 993

www.dvgw-cert.com

info@dvgw-cert.com

Gas Category	Remarks
<i>Gasart</i>	<i>Bemerkungen</i>
fuel gases of the 1., 2. & 3. gas family	

Type	Technical Data	Remarks
<i>Typ</i>	<i>Technische Daten</i>	<i>Bemerkungen</i>
710 Minisit	nominal diameter: DN 15	

Hints of Utilization /Remarks***Verwendungshinweise / Bemerkungen***

max. inlet pressure: 50 mbar

group: 2

class (thermoelectric flame supervision): C

max. ambient temperature range: 0...+80 °C

connection: internal thread 3/8 or 1/2 according to ISO 7-1 (Rp 3/8 or Rp 1/2 according to DIN EN 10226-1)

The multi functional control is equipped optionally with electric ignition device and ignition interlock.